



December 13, 2011

CONTRACT NO. 2012-BT-6
NOVATO BUS FACILITY SECURITY IMPROVEMENTS

To all Prospective Bidders:

The Golden Gate Bridge, Highway and Transportation District (District) herewith issues the attached document entitled, “**QUESTIONS AND RESPONSES FROM POTENTIAL BIDDERS NO. 3,**” which is in response to inquiries submitted by prospective Bidders to the District.

Should you have any questions regarding the foregoing, please contact Mike Yim, Senior Civil Engineer, by telephone at (415) 923-2018.

A handwritten signature in blue ink that reads "Janet S. Tarantino". The signature is written in a cursive style and is positioned above a horizontal line.

Janet S. Tarantino
Secretary of the District

Attachment: Questions and Responses from Potential Bidders No. 3

December 13, 2011

CONTRACT NO. 2012-BT-6
NOVATO BUS FACILITY SECURITY IMPROVEMENTS

QUESTIONS AND RESPONSES FROM POTENTIAL BIDDERS

Question 23: The specification states to furnish and install alarm contacts on certain gates. Please provide a manufacturer and model with mounting details of these alarm gate contacts.

Response 23: The alarm contacts for the electric gates are Sentrol 2502A or approved equal. The alarm contacts shall come with a mounting bracket that mounts to gate post while the magnet portion will be attached to the gate frame. Welding may be required for the attachments.

Question 24: Is the electrical responsible for all grounding on the fence?

Response 24: District is not aware that the fence requires grounding.